

COMcheck Software Version 4.0.7.0
Interior Lighting Compliance Certificate

Project Information
Energy Code: 2015 IECC
Project Title: New Construction
Project Type: New Construction
Construction Site: Owner/Agent: Designer/Contractor:

Additional Efficiency Package
Reduced interior lighting power. Requirements are implicitly enforced within interior lighting allowance calculations.

Allowed Interior Lighting Power

A Area Category	B Floor Area (ft ²)	C Allowed Watts / ft ²	D Allowed Watts (B X C)
1-Retail	2500	1.13	2835
Total Allowed Watts =			2835

Proposed Interior Lighting Power

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps / Fixture	C # of Fixtures	D Fixture Watt.	E (C X D)
1-Retail LED 1: LG2-XX: LED Panel 38W:	1	23	40	920
LED 2: ML3: LED PAR 20W:	3	13	60	780
LED 2 copy 1: ML1: LED PAR 20W:	1	10	20	200
LED 4: EF: LED A Lamp 25W:	1	1	25	25
Total Proposed Watts =				1925

Interior Lighting PASSES: Design 32% better than code

Interior Lighting Compliance Statement
Compliance Statement: The proposed interior lighting design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed interior lighting systems have been designed to meet the 2015 IECC requirements in COMcheck Version 4.0.7.0 and to comply with any applicable mandatory requirements listed in the Inspection Checklist.

Name - Title: Signature: Date:

Project Title: G:\My Drive\Projects\0241 - T-Mobile 2018\0242.03 - 686 US Hwy 50 & Club Manor Pueblo Report date: 12/14/17
Data filename: G:\My Drive\Projects\0241 - T-Mobile 2018\0242.03 - 686 US Hwy 50 & Club Manor Pueblo Page 1 of 5
CO\ComCheck.cck

Section # & Req.ID	Rough-In Electrical Inspection	Complies?	Comments/Assumptions
C405.2.1 [EL15] 1	Lighting controls installed to uniformly reduce the lighting load by at least 50%.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. Location on plans/spec: E111.E112.E113
C405.2.1 [EL18] 1	Occupancy sensors installed in required spaces.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. Location on plans/spec: E111.E112.E113
C405.2.1 [EL23] 1	Independent lighting controls installed per approved lighting plans and all manual controls readily accessible and visible to occupants.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. Location on plans/spec: E111.E112.E113
C405.2.2 [EL22] 1	Automatic controls to shut off all building lighting installed in all buildings.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. Location on plans/spec: E111.E112.E113
C405.2.3 [EL16] 1	Daylight zones provided with individual controls that control the lights independent of general area lighting.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Exception: Sidelight zones on first floor in Group A-2 and M occupancies.
C405.2.3 [EL20] 1	Primary sidelighted areas are equipped with required lighting controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Exception: Sidelight zones on first floor in Group A-2 and M occupancies.
C405.2.3 [EL21] 1	Enclosed spaces with daylight area under skylights and rooftop monitors are equipped with required lighting controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Exception: Requirement does not apply.
C405.2.4 [EL4] 1	Separate lighting control devices for specific uses installed per approved lighting plans.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. Location on plans/spec: E111.E112.E113
C405.2.4 [EL8] 1	Additional interior lighting power allowed for special functions per the approved lighting plans and is automatically controlled and separated from general lighting.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C405.3 [EL6] 1	Exit signs do not exceed 5 watts per face.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. Location on plans/spec: E111.E112.E113

Additional Comments/Assumptions:

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title: G:\My Drive\Projects\0241 - T-Mobile 2018\0242.03 - 686 US Hwy 50 & Club Manor Pueblo Report date: 12/14/17
Data filename: G:\My Drive\Projects\0241 - T-Mobile 2018\0242.03 - 686 US Hwy 50 & Club Manor Pueblo Page 3 of 5
CO\ComCheck.cck

COMcheck Software Version 4.0.7.0
Inspection Checklist

Energy Code: 2015 IECC
Requirements: 86.0% were addressed directly in the COMcheck software
Text in the "Comments/Assumptions" column is provided by the user in the COMcheck Requirements screen. For each requirement, the user certifies that a code requirement will be met and how that is documented, or that an exception is being claimed. Where compliance is itemized in a separate table, a reference to that table is provided.

Section # & Req.ID	Plan Review	Complies?	Comments/Assumptions
C103.2 [PR4] 1	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the interior lighting and electrical systems and equipment and document where exceptions to the standard are claimed. Information provided should include interior lighting power calculations, wattage of bulbs and ballasts, transformers and control devices.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. Location on plans/spec: E111.E112.E113
C406 [PR9] 1	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the additional energy efficiency package options.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

Additional Comments/Assumptions:

Project Title: G:\My Drive\Projects\0241 - T-Mobile 2018\0242.03 - 686 US Hwy 50 & Club Manor Pueblo Report date: 12/14/17
Data filename: G:\My Drive\Projects\0241 - T-Mobile 2018\0242.03 - 686 US Hwy 50 & Club Manor Pueblo Page 2 of 5
CO\ComCheck.cck

Section # & Req.ID	Final Inspection	Complies?	Comments/Assumptions
C303.3 [F11] 1	Furnished O&M instructions for systems and equipment to the building owner or designated representative.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C405.4.1 [F18] 1	Interior installed lamp and fixture lighting power is consistent with what is shown on the approved lighting plans, demonstrating proposed watts are less than or equal to allowed watts.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Interior Lighting fixture schedule for values.
C408.2.5 [F16] 1	Furnished as-built drawings for electric power systems within 90 days of system acceptance.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C408.3 [F13] 1	Lighting systems have been tested to ensure proper calibration, adjustment, programming, and operation.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.

Additional Comments/Assumptions:

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title: G:\My Drive\Projects\0241 - T-Mobile 2018\0242.03 - 686 US Hwy 50 & Club Manor Pueblo Report date: 12/14/17
Data filename: G:\My Drive\Projects\0241 - T-Mobile 2018\0242.03 - 686 US Hwy 50 & Club Manor Pueblo Page 4 of 5
CO\ComCheck.cck

Firm's License #

State License #

#	DESCRIPTION	DATE
1	BUILDING DEPARTMENT	7/26/17

US HWY 50 & CLUB MANOR DR
908 W US HWY 50
PUEBLO, CO 81008
ENERGY CALCULATIONS

MDC
CORPORATE - RELO
686
DESIGN DEVELOPMENT

DATE: 12/21/2017
SCALE: NO SCALE
DRAWN BY: XXX
PROJECT No.: TMO384
SHEET:

E601